



AENOR Product Certificate



001/007455

AENOR certifies that the organization

FITTINGS ESTANDAR, S.L.

registered office PI ROMICA, AVENIDA D, PARCELA 216 02080 ALBACETE (Spain)

supplies **Flooring heating systems**

in compliance with the standards
UNE-EN 1264-1:2022 (EN 1264-1:2021)
UNE-EN 1264-2:2022 (EN 1264-2:2021)
UNE-EN 1264-3:2022 (EN 1264-3:2021)
UNE-EN 1264-4:2022 (EN 1264-4:2021)
UNE-EN 1264-5:2022 (EN 1264-5:2021)

System description See annex for more information.

Production site PI ROMICA, AVENIDA D, PARCELA 216 02080 ALBACETE (Spain)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.64.

This certificate supersedes 001/007455, dated 2025-01-31

First issued on 2022-11-23
Modified on 2026-02-13
Validity 2027-11-23

Rafael GARCÍA MEIRO
CEO



AENOR Product Certificate

001/007455

Annex to Certificate

System description Trademark: FITTINGS ESTANDAR
Type of structure: Type A
Subtype: A2
Panel trade name: Fittings Standard 23-45
Type of insulating panel: EPS
Thickness declared of the flat part: 23 mm
Thickness declared including molded part: 45 mm
Effective thermal resistance of the panel: 0,77 m²K/W
Panel thermal conductivity: 0,030 W/mK
Type of coating: Mortar with additive FITTINGS ESTANDAR
Thickness of the mortar: 0,045 m
Type of pipe: PE-Xa Pipes (AENOR Cert. 001/006980)
Pipe dimension: 16x1,8 mm

Pipe distance (mm)	Standard specific thermal output q _N (W/m ²)	Standard temperature difference DT(K)	Equivalent thermal transmittance (W/m ² K)	Verification method	Date
100	96,20	17,21	5,59	Experimental	2025-12-17
150	92,64	17,34	5,34	Experimental	2023-12-19
200	87,34	19,50	4,48	Experimental	2024-12-19

First issued on 2022-11-23
Modified on 2026-02-13
Validity 2027-11-23

